

SPP Transmission Topology Optimization Pilot

EFFICIENT CONGESTION MANAGEMENT AND OVERLOAD MITIGATION THROUGH SYSTEM RECONFIGURATIONS

PRESENTED BY

Pablo A. Ruiz

Pablo.Ruiz@brattle.com

Brattle and NewGrid

Jay Caspary

jcaspary@spp.org

SPP

ESIG Spring Technical Workshop

Bernalillo, NM

March 20, 2019



THE **Brattle** GROUP




SPP *Southwest
Power Pool*

Topology Optimization


Topology optimization complements resource-based congestion management by automatically finding reconfigurations to route flow around congested elements (“Waze for the transmission grid”).

Example:

SPP Real Time Prices
March 10, 2018, 20:10 CST
38% Wind Penetration




Historical Case



With Reconfigurations (3 actions, one per historical constraint)

*NewGrid Router
Topology
Optimization
Software*


*“Open/Close
Circuit Breakers X,
Y and Z”*



Reconfiguration Practice


Traditional/Today

- Reconfigurations are employed on an ad-hoc basis
- Reconfigurations are identified based on staff experience (time-consuming process)
- The transmission grid flexibility is underutilized



With Topology Optimization


- Software identifies reconfiguration solution *options* to select
- Fast identification: 10 sec – 2 min
- Facilitate training of new operators
- Take full advantage of grid flexibility
- Achieve better outcomes



Reconfigurations Meet Reliability Criteria

NewGrid Router runs contingency analysis to ensure that the new configurations are feasible (e.g., do not cause new contingency violations).


- Preventive solutions: reconfigure in base case
- Corrective solutions: reconfigure if contingency occurs




SPP Study: Constraint Flow Relief Effectiveness

- SPP selected 20 real-time snapshots with congestion/overloads on focus constraints.
- Brattle identified reconfiguration options using *NewGrid Router*, SPP validated them on the EMS.
- **Feasible** Solution: meets pre- and post-contingency criteria, validated in the EMS
- **Preferred** Solution by SPP, in addition:
 - Loading on any new constraints below 95%
 - Comprises a single action below 345 kV
 - Radializes less than 30 MW of load
 - Provides at least 10% relief

Best Solution by Constraint



Average Flow Relief by Constraint



Now Let's Discuss Field Results from SPP...



Transmission Topology Optimization Pilot with SPP Operations – Results

ESIG 2019 Spring Technical Workshop
Session 4: Preparing for Future Energy Systems

Jay Caspary

Director – Research, Development & Tariff Services

jcaspary@spp.org, 501.614.3220 (o), 501.951.3296 (m)




HELPING OUR MEMBERS WORK TOGETHER
TO KEEP THE LIGHTS ON... TODAY AND IN THE FUTURE.

Topology Optimization Pilot Overview

- SPP Operations conducted a pilot with the NewGrid Router topology optimization tool (Q3 2018 – Q4 2018)
- Operations Analysis & Planning (Reliability focus)
 - Focus was on finding ‘preferred’ solutions:
 - At least 5% N-1 loading reduction
 - Up-to 30 MW newly radialized load
 - Single switching action
 - 230 kV or below only (230 kV XFR low side)
 - No resultant constraint loading over 95% post-contingent
 - Evaluated 100 flowgates with congestion during real-time operations
 - Found ‘preferred’ solutions to 55 flowgates
- Some reconfigurations were used in real-time operations:
 - Johnson County – Russet Op Guide
 - Mitigation of the DARCLAANOFTS permanent flowgate


SPP Topology Optimization Pilot Example Locations



Real-time Solution Example

- In August 9, 2018 SPP Operations was experiencing a post-contingent overload on the DARCLAANOFTS permanent flowgate
- This constraint can be challenging to control due to significant external parallel flow impacts
- Real-time staff requested Operations Support to perform a Topology Control assessment of this constraint
- Operations Support was able to quickly identify a pre-contingent mitigation plan which reduced the constraint flow by over 20% and eliminated the post-contingent overload


Router Mitigation: Open the Clarksville – Little Spadra 161 kV line pre-contingent



Confirmation of existing mitigation plans

- SPP also found Router useful as a means to ensure that existing mitigation plans are the most effective and efficient
- Example existing plan check:
 - Constraint: Butler – Altoona 138 kV (flo) Caney River – Neosho 345 kV
 - Existing Mitigation: Open Butler – Midian 138 kV
 - Router quickly found the same mitigation solution!

Router Mitigation: Open Butler - Midian138 kV line



Congestion during High Wind Penetration Intervals

- SPP transmission can be exposed to heavy transfers of wind generation during high wind & low load conditions
- These transfers typically flow from West to East across SPP
- Constraints exposed to these system transfers and located far away from generation can be difficult to control, as generation shift factors are too low for the market to effectively redispatch resources
- Example high wind transfer constraint:
 - Constraint: Stonewall – Tupelo 138 kV (flo) Pittsburg – Valliant 345 kV
 - Router Solution: Open Civit – Stratford 138 kV for 24% relief
 - Newly radialized load < 10 MW
- Topology Optimization made it possible to quickly find a solution while minimizing the amount of load radialized

Router Mitigation: Open the Civit – Stratford 138 kV line



Appendix Contents


Appendix 1: Reliability and Market Benefits

Appendix 2: References

Reliability Benefits – Breached Constraint Relief

Topology optimization can significantly reduce the frequency of breached constraints in the markets without incurring additional costs.

- Real-time system conditions differ from those planned day-ahead.
- Operators have limited means to manage some constraints in real time.



Sources:

Historical: SPP State of the Market Report 2017.

* We conservatively assume that the use of topology optimization in RT Operations could provide breach constraint relief in 75% of the observed breached constraints; in the study of the 20 selected historical constraints, 95% of them were relieved to well below their limit.

Market Simulation Methodology

Constraint relief in the previous slides were based on the historical dispatch. We assessed real-time markets savings for four out of the twenty cases selected by SPP.


- We simulated the real-time market for four cases and evaluated the reduced congestion costs of applying reconfigurations to relieve constraints in those cases.
- Base case market results benchmarked against the historical market dispatch and shadow prices.
- Conservative assumptions:
 - We fixed the dispatch of 25-85 units (out of 200-250 market-dispatchable units) to the historical dispatch level so as to achieve market simulation results that meet the benchmark.
 - Because we removed many units as decision variables from the market, we are most likely underestimating the savings achievable by relieving bindings constraints.

Appendix 1 – Reliability and Market Benefits

Market Efficiency Benefits

Topology optimization would provide **annual Real Time Market savings of over \$18-44 million** when used in market optimization.

- Based on the cases simulated, the real-time market cost savings provided by topology optimization is about 3% (+2%/-1%) of the initial *congestion rent* of the constraints relieved.
- We extrapolated the market savings based on the historical Real Time Market congestion rent (\$1.2 billion in 2017), conservatively assuming that topology optimization can effectively provide relief for 75% of the constraints.*



* In the study of the 20 selected historical constraints, 95% of them were relieved with topology optimization.

Appendix 2

References (I/II)

- [1] P. A. Ruiz et al, "Transmission topology optimization: congestion relief in operations and operations planning," presented at *SPP Market Working Group Meeting*, Oct 2018. [Online]
<https://spp.org/Documents/58737/MWG%20Agenda%20&%20Background%20Materials%2020181009%2010.zip>
- [2] P. A. Ruiz et al, "Transmission topology optimization: performance and benefit assessment in SPP Operations and Operations Planning," presented at *SPP Operating Reliability Working Group Meeting*, Little Rock, AR, May 2018. [Online]
<https://www.spp.org/Documents/57991/ORWG%20Meeting%20Materials%205-30-18.zip>
- [3] P. A. Ruiz, "Power Flow Control Through Topology Optimization Software: Applications and Case Studies," presented at *IEEE PES Transmission & Distribution Conference and Expo*, Denver, CO, April 2018.
- [4] P. A. Ruiz, "Transmission topology optimization: operations and market applications and case studies," presented at *ERCOT Demand Side Working Group Meeting*, Austin, TX, Nov 2017. [Online]
http://ercot.com/content/wcm/key_documents_lists/127739/PRuiz_ERCOT_DSWG_FINAL.pdf
- [5] National Grid Electricity Transmission Network Innovation Allowance Annual Summary 2016/2017, Jul 2017, page 14. [Online]
<https://www.nationalgrid.com/sites/default/files/documents/National%20Grid%20Electricity%20Transmission%20NIA%20Annual%20Summary%202016-17.pdf>
- [6] National Grid, Network Innovation Allowance Closedown Report, Transmission Network Topology Optimisation, project NIA_NGET0169, Jul 2017. [Online] http://www.smarternetworks.org/project/nia_nget0169/documents
- [7] P. A. Ruiz, "Transmission topology optimization software: operations and market applications and case studies," presented at *ERCOT Emerging Technologies Working Group Meeting*, Austin, TX, Dec 2016. [Online]
http://www.ercot.com/content/wcm/key_documents_lists/85542/05.Transmission_topology_control_--_ERCOT_ETWG_12616.pdf
- [8] P. A. Ruiz, "Transmission topology optimization software: operations and market applications and case studies," *SPP Technology Expo*, Little Rock, AR, Nov 2016. [Online] https://www.spp.org/Documents/45058/Tech_Expo_11_14_16_Agenda_&_20Presentations.zip
- [9] P. A. Ruiz et al, "Transmission topology optimization: simulation of impacts in PJM day-ahead markets," presented at *FERC Tech. Conf. on Increasing Market Efficiency through Improved Software*, Docket AD10-12-007, Washington, DC, June 2016.
- [10] P. A. Ruiz, E. A. Goldis, A. M. Rudkevich, M. C. Caramanis, C. R. Philbrick, and J. M. Foster, "Security-constrained transmission topology control MILP formulation using sensitivity factors," *IEEE Trans. on Power Systems*, vol. 32, no. 2, Mar 2017, pp. 1597 – 1605. <https://ieeexplore.ieee.org/abstract/document/7881111>

- [11] E. A. Goldis, P. A. Ruiz, M. C. Caramanis, X. Li, C. R. Philbrick, A. M. Rudkevich, “Shift factor-based SCOPF topology control MIP formulations with substation configurations,” *IEEE Trans. on Power Systems*, vol. 32, no. 2, Mar 2017, pp. 1179 – 1190.
- [12] J. Chang and P. A. Ruiz, “Transmission Topology Control – Applications to Outage Scheduling, Market Efficiency and Overload Relief,” presented at *WIRES Summer Meeting*, Boston, MA, July 2015.
- [13] P. Ruiz et al, “Topology Control Algorithms (TCA) – Simulations in PJM Day Ahead Market and Outage Coordination,” pres. at *FERC Tech. Conf. Increasing Market Efficiency through Improved Software*, Docket AD10-12-006, Washington, DC, June 2015.
- [14] E. A. Goldis, X. Li, M. C. Caramanis, A. M. Rudkevich, P. A. Ruiz, “AC-Based Topology Control Algorithms (TCA) – A PJM Historical Data Case Study,” in *Proc. 48th Hawaii Int. Conf. System Science*, January 2015.
- [15] P. A. Ruiz, X. Li, and B. Tsuchida, “Transmission Topology Control – Curtailment Reduction through System Reconfiguration,” presented at *Utility Variable-Generation Integration Group Fall Technical Workshop*, San Antonio, TX, October 2014.
- [16] P. A. Ruiz et al, “Transmission Topology Control for System Efficiency: Simulations on PJM Real Time Markets,” presented at *2013 IEEE PES General Meeting*, Vancouver, Canada, July 2013.
- [17] P. A. Ruiz, J. M. Foster, A. Rudkevich and M. C. Caramanis, “Tractable transmission topology control using sensitivity analysis,” *IEEE Transactions on Power Systems*, vol. 27, no. 3, Aug 2012, pp. 1550 – 1559.
- [18] J. M. Foster, P. A. Ruiz, A. Rudkevich and M. C. Caramanis, “Economic and corrective applications of tractable transmission topology control,” in *Proc. 49th Allerton Conf. on Communications, Control and Computing*, Monticello, IL, September 2011.
- [19] P. A. Ruiz, J. M. Foster, A. Rudkevich and M. C. Caramanis, “On fast transmission topology control heuristics,” in *Proc. 2011 IEEE Power and Energy Soc. Gen. Meeting*, Detroit, MI, July 2011.
- [20] R. O’Neill, R. Baldick, U. Helman, M. Rothkopf, and W. Stewart, “Dispatchable transmission in RTO markets,” *IEEE Transactions on Power Systems*, vol. 20, no. 1, pp. 171–179, Feb. 2005.
- [21] E. B. Fisher, R. P. O’Neill, and M. C. Ferris, “Optimal transmission switching,” *IEEE Transactions on Power Systems*, vol. 23, no. 3, pp. 1346–1355, Aug. 2008.
- [22] K. W. Hedman, R. P. O’Neill, E. B. Fisher, and S. S. Oren, “Optimal transmission switching with contingency analysis,” *IEEE Transactions on Power Systems*, vol. 23, no. 3, pp. 1577–1586, Aug. 2009.